

Your Partner for a Healthy Community

Environmental Health Division 55 Brown Road, Ithaca, NY 14850 (607) 274-6688; Fax (607) 274-6695

CERTIFICATE OF COMPLETION OF SEWAGE TREATMENT SYSTEM

Date:

05/14/2012

Owner's Name:

ORSON R LEDGER

Property Location:

1459 MECKLENBURG RD

(Town) (Village) (City):

Town Of (6) Ithaca

Tax Map Number:

28.-1-4

Design Basis: 390 gallons per day

Equivalent to: 3 bedrooms

Construction Type: Replacement Sewage System

The individual onsite sewage treatment system installed at the above noted premises has been constructed in general conformity with the requirements of the Tompkins County Health Department and as described on the Permit to Construct a Sewage Treatment System.

"UNABLE TO MAINTAIN A 100 FOOT SEPARATION DISTANCE FROM THE SEWAGE SYSTEM TO THE WELL. WELL IS 34 FEET TO THE SANDFILTER BED. RECOMMEND TESTING THE WELL ON A ROUTINE BASIS."

&ignature

Ithaca, Town Of (6) CEO

To help extend the useful life of your sewage treatment system, the septic tank should be pumped every 2 to 4 years depending upon the amount of solids such as greases, soap scum, toilet wastes, and other solid materials discharged to the tank. When combined depth of sludge and scum in the tank equals or exceeds 1/4 of the total liquid depth, pumping is necessary. Checking the scum and sludge depth should be performed by a professional or someone familiar with septic tanks. Tanks are best pumped in the spring or summer as they adjust more readily in warm weather. Inlet and outlet baffles in the tank should be checked at the time of pumping.

A list of authorized pumpers may be obtained from the Health Department. It will be to your advantage to insist on a fixed cost for pumping or at least to obtain a definite maximum estimate before engaging a septic tank pumper.

Normal use of household detergents and chemicals will not harm your system. Do not discard non-household substances into your system, such as motor oil, antifreeze, etc. This is illegal, will contaminate ground water and will ruin your system. Contact the Tompkins County Solid Waste Division for information on discarding or recycling toxic chemicals not intended for your sewage system.

If repairs or replacement of the system become necessary, a new permit from the Health Department will be required.

If triangulation distances to the septic tank and distributions boxes could be obtained, they will be noted on the back of this sheet. These measurements will help find the tank pumping, and the distribution box should the system need troubleshooting in the event of failure or poor performance.

RIANGULLATIONS

21459 Mecklenberg Road

(T) Ithacau

TAX # 28,-1-4 Not 1 Not to scale prepart. 3 bearoom House Joses 341 ANDELLEY, Pipeci Trench & x 46' Top of read Bank