

TOMPKINS COUNTY DEPARTMENT OF HEALTH



Willard C. Schmidt, M.D., M.P.H.
Commissioner of Health

APPROVAL OF SEWAGE DISPOSAL SYSTEM

1287 Trumansburg Road
Ithaca, New York
Phone 273-7272

Environmental Health Div
607-273-7275

CERTIFICATE OF COMPLETION

Date: November 27, 1984

Owner's Name: Winifred Donahue

Property Location: 1684 Mecklenburg Road

(Town) (Village) (City): Enfield (T)

Tax Map Number: 4-4-2-24

DESIGN BASIS: Not to exceed 450 gallons sewage per day. For a dwelling, this is equivalent to 3 bedrooms.

I hereby certify that the private sewage disposal facilities installed at the above noted premise have been constructed in general conformity with the regulations of the Tompkins County Department of Health and the plans on file in this office, thus fulfilling the requirements of the Tompkins County Sanitary Code.

Audrey Balanda
Signature

To help extend the useful life of your disposal system, the septic tank should be cleaned every 2 to 4 years depending upon the amount of solids such as greases, soap scum, toilet wastes, and other solid materials discharged to the tank. If possible, the sludge and scum depth should be checked every year. When combined depth of sludge and scum equal $1/4$ of the total liquid depth, cleaning is necessary. Septic tanks are best cleaned in the spring or summer as they become readjusted more readily in warm weather. Condition of the baffles in the tank should be checked at the time of cleaning.

A list of persons authorized to clean septic tanks in this County may be obtained from the Health Department. It will be to your advantage to insist on a fixed cost for cleaning or at least to obtain a definite maximum estimate before engaging a septic tank cleaner.

Normal use of household detergents and chemicals will not be harmful to your disposal system. Avoid use of so-called septic tank cleaners or conditioners as they have not been shown to be beneficial and they may result in actual harm to the system.

If repairs or replacement of the system become necessary, a new permit from this Department will be required.

TOMPKINS COUNTY HEALTH DEPARTMENT
 1287 Trumansburg Road, Ithaca, N.Y. 14850
 (607-273-7275)

SEWAGE TREATMENT SYSTEM CONSTRUCTION PERMIT

FOR: WINIFRED DONAHUE

LOCATION: 1684 MECKLENBURG TAX MAP NO. 4-4-2-24

Permit valid for sewage flows NOT in excess of 450 gallons per day (..... 3 bedroom house or equivalent). Valid for inclusion of garbage grinder wastes YES NO

In accordance with the provisions of the County Sanitary Code, you are hereby granted permission to construct a private sewage treatment system at the above location with the sketch and details shown herein or previously provided.

DATE 1/16/84 INSPECTOR Audrey Belandier

This permit is not transferable to another person or property.

This permit is valid for one (1) year from date of issuance. If construction is not completed within this period, your application must be updated by the Health Department.

INSPECTORS COMMENTS

Inspection Checklist

u/21/84 Bottom inspection OK	Yes	No
	Proper S.T. size	
D.B. level		
Proper pipe grades		
Trench depth		
Stone and Sand depth		
Straw cover		
6"-12" topsoil		
Surface grading		

SEWAGE TREATMENT SYSTEM

