



Your Partner for a Healthy Community

Environmental Health Division
401 Harris B. Dates Drive, Ithaca, NY 14850
(607) 274-6688; Fax (607) 274-6695

CERTIFICATE OF COMPLETION OF SEWAGE TREATMENT SYSTEM

Date: 08/13/2008
Owner's Name: ORSON LEDGER
Property Location: 1720 MECKLENBURG RD
(Town) (Village) (City): Town Of (4) Enfield
Tax Map Number: 4.-1-10
Design Basis: 330 gallons per day Equivalent to: 3 bedrooms
Construction Type: Replacement Sewage System

The individual onsite sewage treatment system installed at the above noted premises has been constructed in general conformity with the requirements of the Tompkins County Health Department and as described on the Permit to Construct a Sewage Treatment System.

A handwritten signature in black ink, appearing to be "R. M. [unclear]", is written over a horizontal line.

Signature

CC: Enfield, Town Of (4) CEO

To help extend the useful life of your sewage treatment system, the septic tank should be pumped every 2 to 4 years depending upon the amount of solids such as greases, soap scum, toilet wastes, and other solid materials discharged to the tank. When combined depth of sludge and scum in the tank equals or exceeds 1/4 of the total liquid depth, pumping is necessary. Checking the scum and sludge depth should be performed by a professional or someone familiar with septic tanks. Tanks are best pumped in the spring or summer as they adjust more readily in warm weather. Inlet and outlet baffles in the tank should be checked at the time of pumping.

A list of authorized pumpers may be obtained from the Health Department. It will be to your advantage to insist on a fixed cost for pumping or at least to obtain a definite maximum estimate before engaging a septic tank pumper. Normal use of household detergents and chemicals will not harm your system. Do not discard non-household substances into your system, such as motor oil, antifreeze, etc. This is illegal, will contaminate ground water and will ruin your system. Contact the Tompkins County Solid Waste Division for information on discarding or recycling toxic chemicals not intended for your sewage system. If repairs or replacement of the system become necessary, a new permit from the Health Department will be required.

If triangulation distances to the septic tank and distributions boxes could be obtained, they will be noted on the back of this sheet. These measurements will help find the tank pumping, and the distribution box should the system need troubleshooting in the event of failure or poor performance.

SEWAGE TREATMENT SYSTEM CONSTRUCTION PERMIT
TOMPKINS COUNTY HEALTH DEPARTMENT
 401 Harris B. Dates Drive, Ithaca, NY 14850-1386 (607)274-6688 Fax (607)274-6695
 Your partner for a healthy community.

For: ORSON R. LEDGER Permit # SP2008-657

Location: 1720 MECKLENBURG ROAD Tax Map # 4-4-1-10

Permit valid for design flow not in excess of 330 gallons per day (3 bedroom house or equivalent).

Valid for inclusion of garbage grinder wastes Yes No Toilet volume per flush 1.6 gallons.

Based on the application information provided, and in accordance with the provisions of the County Sanitary Code, you are hereby granted permission to construct a sewage treatment system at the above location. Significant changes could invalidate the permit.

This permit is valid for two years from date of issue. Permit may be renewed for a period of two more years, or transferred to another person, if application is made prior to expiration.

Inspector: R. EWALD Date: 8-10-2008

INSPECTOR'S COMMENTS

Inspection Checklist

	Yes	No	NA
Distance From Well			
Proper ST Size			
DB Level			
Proper Pipe Grades			
Trench Depth			
Stone and Sand Depth			
Pea Gravel			
Straw Cover/Permeable Geotextile			
6-12 inch Topsoil			
Surface Grading			

SKETCH FOR APPROVED DESIGN OF SEWAGE TREATMENT SYSTEM

Minimum lot size required for this sewage system is _____ usable area which can contain a _____ feet diameter circle. Lot size may NOT be reduced below this minimum without Health Department approval.

