



Your Partner for a Healthy Community

Frank Kruppa  
Public Health Director

55 Brown Road  
Ithaca, NY 14850-12477

ENVIRONMENTAL HEALTH DIVISION

<http://www.tompkins-co.org/health/eh>

Ph: (607) 274-6688

Fx: (607) 274-6695

### CERTIFICATE OF COMPLETION OF SEWAGE TREATMENT SYSTEM

**Date:** 08/26/2013

**Owner's Name:** ORSON R LEDGER

**Property Location:** 1862 TRUMANSBURG RD


**(Town) (Village) (City):** Town Of (9) Ulysses

**Tax Map Number:** 25.-6-15

**Design Basis:** 440 gallons per day **Equivalent to:** 4 bedrooms

**Construction Type:** Replacement Sewage System

The individual onsite sewage treatment system installed at the above noted premises has been constructed in general conformity with the requirements of the Tompkins County Health Department and as described on the Permit to Construct a Sewage Treatment System.

  
Signature

CC: Ulysses, Town Of (9) CEO

To help extend the useful life of your sewage treatment system, the septic tank should be pumped every 2 to 4 years depending upon the amount of solids such as greases, soap scum, toilet wastes, and other solid materials discharged to the tank. When combined depth of sludge and scum in the tank equals or exceeds 1/4 of the total liquid depth, pumping is necessary. Checking the scum and sludge depth should be performed by a professional or someone familiar with septic tanks. Tanks are best pumped in the spring or summer as they adjust more readily in warm weather. Inlet and outlet baffles in the tank should be checked at the time of pumping.

A list of authorized pumpers may be obtained from the Health Department. It will be to your advantage to insist on a fixed cost for pumping or at least to obtain a definite maximum estimate before engaging a septic tank pumper. Normal use of household detergents and chemicals will not harm your system. Do not discard non-household substances into your system, such as motor oil, antifreeze, etc. This is illegal, will contaminate ground water and will ruin your system. Contact the Tompkins County Solid Waste Division for information on discarding or recycling toxic chemicals not intended for your sewage system. If repairs or replacement of the system become necessary, a new permit from the Health Department will be required.

If triangulation distances to the septic tank and distributions boxes could be obtained, they will be noted on the back of this sheet. These measurements will help find the tank pumping, and the distribution box should the system need troubleshooting in the event of failure or poor performance.

System component	A (ft)	B (ft)	C (ft)	D (ft)
Septic tank outlet (1250gal.)	28	12	23	30
Pump chamber (750gal.)	29	17	30	37
Distribution Box #1	67	63	74	81
End of Sand Filter	66	75	NA	97
Distribution Box #2	54	63	NA	87
PC to DB #1	49			
End of Filter to DB#2	6			

**NOT TO SCALE**

