

TOMPKINS COUNTY DEPARTMENT OF HEALTH

APPROVAL OF SEWAGE DISPOSAL SYSTEM

SUZANNE R. STOPEN, R.N., M.P.S.
Public Health Director

CERTIFICATE OF COMPLETION

Environmental Health Division
401 Harris B. Dales Drive
Ithaca, New York 14850-1388
607-274-6688

Date: 11/13/91
Owner's Name: Katherine M. Lattin
Property Location: 551 Brooktondale Road
(Town) (Village) (City): (TO Caroline
Tax Map Number: 1-10-1-7

DESIGN BASIS: Not to exceed 450 gallons sewage per day. For a dwelling, this is equivalent to 3 bedrooms.

I hereby certify that the private sewage disposal facilities installed at the above noted premise have been constructed in general conformity with the regulations of the Tompkins County Department of Health and the plans on file in this office, thus fulfilling the requirements of the Tompkins County Sanitary Code.


Signature

To help extend the useful life of your disposal system, the septic tank should be cleaned every 2 to 4 years depending upon the amount of solids such as greases, soap scum, toilet wastes, and other solid materials discharged to the tank. If possible, the sludge and scum depth should be checked every year. When combined depth of sludge and scum equal 1/4 of the total liquid depth, cleaning is necessary. Septic tanks are best cleaned in the spring or summer as they become readjusted more readily in warm weather. Condition of the baffles in the tank should be checked at the time of cleaning.

A list of persons authorized to clean septic tanks in this County may be obtained from the Health Department. It will be to your advantage to insist on a fixed cost for cleaning or at least to obtain a definite maximum estimate before engaging a septic tank cleaner.

Normal use of household detergents and chemicals will not be harmful to your disposal system. Avoid use of so-called septic tank cleaners or conditioners as they have not been shown to be beneficial and they may result in actual harm to the system.

If repairs or replacement of the system become necessary, a new permit from this Department will be required.

SEWAGE TREATMENT SYSTEM CONSTRUCTION PERMIT
TOMPKINS COUNTY HEALTH DEPARTMENT
 401 HARRIS B. DATES DRIVE, ITHACA, NY 14850-1386
 (607) 273-7275

FOR: KIM WHETZEL

LOCATION: 551 BROOKTONDALE RD TAX MAP NO. 1-10-1-7

Permit valid for sewage flows not in excess of 450 gallons per day (3 bedroom house or equivalent). Valid for inclusion of garbage grinder wastes YES NO

In accordance with the provisions of the County Sanitary Code, you are hereby granted permission to construct a private sewage treatment system at the above location with the sketch and details shown herein or previously provided.

This permit is not transferable to another person or property.

This permit is valid for one (1) year from date of issuance. If construction is not completed within this period, your permit must be updated by the Health Department.

DATE 11-23-91 INSPECTOR R. EWALD

INSPECTORS COMMENTS

*11-13-91 inspected
 Δ distances inside*

Inspection Checklist

	Yes	No
Proper S.T. size	<input checked="" type="checkbox"/>	<input type="checkbox"/>
D.B. level	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Proper pipe grades	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Trench depth	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Stone and Sand depth	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Straw cover	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6" - 12" topsoil	<input type="checkbox"/>	<input type="checkbox"/>
Surface grading	<input type="checkbox"/>	<input type="checkbox"/>

DESIGN FOR SEWAGE TREATMENT SYSTEM

Minimum lot size required for this sewage system is REPAIR PERMIT usable area which can contain a feet diameter circle. Lot size may not be reduced below this minimum without Health Department approval.

NOT TO SCALE

DUE TO LOT CONSTRAINTS, THE SEWAGE SYSTEM DESIGNED WILL NOT CONFORM WITH CURRENT DESIGN STANDARDS. SEPERATION DISTANCES TO THE WELL AND TO PROPERTY LINES WILL NOT BE MET.

